

### New Generation VVER-1200 Pilot Unit Specific Commissioning Features

V.P. Povarov Manager of Novovoronezh NPP Branch of JSC Concern Rosenergoatom

### Introduction

VVER-1200 (V-392M reactor plant): evolutionary design of large-power NPP





### Brief Power Unit Characteristic Schematic Diagram of NV NPP-2 Power Unit



### Safety Assurance Principles





### Brief Power Unit Characteristic Main Parameters

Rated electric power ww	1198
	1170
Rated thermal power, ww	3200
Rated primary circuit pressure, MPa	16,2
Rated steam generator pressure, MPa	6,9
Number of fuel assemblies	163
Maximum enrichment	4,95
Core damage frequency	2x10 <sup>-7</sup>
Maximum credible earthquake Design-basis earthquake,	7 6
point	



#### Nuclear Island Reactor plant



#### Reactor Plant and Primary Circuit Components Main characteristics

Power, MW	1195,4		
Thermal power, MW	3200		
Core pressure, MPa	16,2 MPa		
Flow rate across the core, (m³/h)	88000		
Coolant temperature at core inlet/outlet, (°C)	298,2/328,6		
RCP	4 Q=22000 m³/h H=0.59 MPa		
Steam generator	4 (horizontal) Pnom.=6.9 MPa Gnom.=1600 t/h		
Hydro-accumulators Passive core flooding	1 <sup>st</sup> stage HAs 4 * 50 m <sup>3</sup> , P=5.9 MPa 2 <sup>nd</sup> stage HAs 8 * 120 m <sup>3</sup> , P=0.1 MPa		



#### Reactor Plant and Primary Circuit Components Reactor Pressure Vessel





### Reactor pressure vessel (RPV) differences from standard reactor plant RPV

- diameter increased by 100 mm;
- length increased by 300 mm;
- limited nickel content in base and weld metal;
- location of surveillance specimens directly on reactor pressure vessel wall



### Reactor Plant and Primary Circuit Components **Core**





#### Reactor Plant and Primary Circuit Components Steam Generator





#### Reactor Plant and Primary Circuit Components Reactor Coolant Pump



Name of parameter	Value
Pump capacity, m <sup>3</sup> /h	22600
Pump head, MPa	0,610+0,025
Coolant temperature, °C	<b>298,2</b> <sup>+2</sup> _4
Rated suction pressure, MPa	16,02
Design temperature, °C	350
Design excessive pressure, MPa	17,64
(Synchronous) speed of rotation, rev./min.	1000/750
Power consumed by RCP-1391 in hot mode, kW, not more than	5000
Maximum power consumed by RCP-1391 in cold state, kW, not more than	6800
Rated feed current voltage, V	6000
Feed current frequency, Hz	50



#### Reactor Plant and Primary Circuit Components Pressurizer



Name of parameter	Value	
Rated steady-state mode (absolute) pressure,	16,1+0,3	
MPa		
Design pressure, MPa	17,64	
Pressurizer coolant temperature under rated steady-state mode.°C	347,9	
Design temperature, °C	350	
Coolant level under rated mode, mm	8170±150	
Total pressurizer volume, m	79	
Coolant volume under rated steady-state	55	
mode, m		
Coolant volume at reactor plant zero power (corresponding to pressurizer coolant level of 5,1 m), m <sup>3</sup>	38,7	



### Safety Systems Composition of active and passive safety systems

- 2 emergency power supply trains
- 2 trains of low pressure ECCS with 2 ECCS heat exchangers
- 2 trains of high pressure ECCS with an ejector
- 2 boron injection trains
- 2 spray system trains (perform the function of spent fuel pool cooling in normal operation modes)
- 2 trains of SG emergency cooldown (with low-pressure pumps and closed-circuit operation for unlimited time)
- 2 trains of support systems for heat removal to ultimate heat sink, including 2 spray ponds
- 2 control system trains
- 4 groups of 2<sup>nd</sup> stage hydro-accumulators
- 4 trains of SG passive heat removal system
- System for melted core confinement and cooling
- System for removal of non-organized gas leakages from inter-containment space



## Safety Systems ECCS and Support Systems (1JNA)



System for primary circuit emergency and planned cooldown and spent fuel pool cooling is intended for:

- reactor plant cooldown under all modes of unit operation;

- residual heat removal from reactor fuel to component cooling circuit;

- residual spent fuel pool heat removal under all modes of unit operation;

- chemicals injection into primary circuit to fix radioactive iodine in case of accidents involving primary circuit leaks;

- maintaining reactor coolant inventory in case of 'large leak' and emergency make-up during 'small leaks';

- emergency core cooldown and subsequent long-term residual heat removal in case of accidents related to primary circuit depressurization, including ND850 total cross-section pipeline rupture;

- performing the function of spray pumps under beyonddesign-basis accident.

#### It has a double-train structure

## Safety Systems Second-stage hydro-accumulator system (1JNG10-40)



Second-stage hydro-accumulators of the passive core flooding system are intended for:

- passive supply of boron solution with concentration of 16 g/dm<sup>3</sup> for core flooding in case of loss-of-coolant accidents when the coolant level is low and the primary circuit pressure drops below 1,5 MPa.
- boron solution storage to fill refueling pool compartments at the unit shutdown for refueling outage.



### Safety Systems System for emergency heat removal through SGs (1JNB10-40)



System for SG emergency cooldown is meant for:

- reactor core residual heat removal and reactor plant cooldown in emergency situations related to loss of power supply or normal heat removal through secondary circuit, including SG steam and feedwater pipeline leaks;

- reactor core residual heat removal and reactor plant cooldown in emergency situations related to primary circuit depressurization, including main circulation pipeline break and primary-to-secondary leak.

#### It has a double-train structure



### Safety Systems Passive SG heat removal (1JNB50-80)

Passive four-train system with train redundancy of 4 x 33 %, with 2 AIR-cooled heatexchangers (of 8 MW each) in each train (time of operation is unlimited)

Passive heat removal system is a protective safety system based on the passive principle of operation that assures reactor core residual heat removal via the secondary circuit



## Safety Systems Double-wall containment



#### росэнергоатом НОВОВОРОНЕЖСКАЯ АЭС

#### Containment diameter (m)

Internal containment wall: 44 External containment wall: 51.8

Maximum excessive pressure (MPa)

0,4

### Safety Systems Melted Core Confinement and Cooling System (1JKM)





## Safety Systems Spray System (1JMN)

Active double-train system



Spray system is designed to perform the function of parameter (pressure and temperature) reduction inside the containment and the function of radioactive iodine fixation



## Safety Systems System for emergency containment hydrogen removal (1JMT)

The JMT system assures hydrogen non-explosiveness in the containment. The system uses passive hydrogen recombiners which are installed in the locations of its possible accumulation. Platinum is used as a catalyst.



#### Safety Systems BDBA management. Additional facilities and systems

The following additional facilities and systems are integrated in the design:

- Emergency diesel-generator plant;
- Mobile pumping unit;
- Mechanical-draft cooling tower;
- Air-bottle station for MCR/RSP habitability assurance;
- Emergency and post-emergency monitoring system;
- Emergency and post-emergency sampling system;
- Diverse protections system.



## Turbo-generator part **Turbine system**

Turbine system	K-1200-6,8/50		
Turbine system diagram	2LPT+HPT+2LPT		
Regenerative heating diagram	4LPH+D+2HPH		
Mass steam flowrate (t/h)	6461,5		
Steam pressure (MPa)	6,8		





### Turbo-generator part **Turbo-generator**



**TZV-1200-2AUZ:** water cooling, power of 1200MW, speed of rotation: 3000 rev./min., six-phase design, two 24 kV three-phase windings are shifted relatively to each other by 30 degrees (50% of rated power each)



### Electric Power Supply Power Delivery Diagram





### Electric Power Supply Diagram of power delivery and unit auxiliaries

#### Gas-insulated 220 kV switchgear





Distinctive features of gas-insulated switchgear are as follows:

- economic efficiency
- high operational reliability
- reliable insulation
- high leak-tightness
- long operation
- low operating costs
- good components access and ergonomics
- high degree of availability
- reliable operation even in extreme weather conditions



### Electric Power Supply Diagram of power delivery and unit auxiliaries

#### Facilities circuit diagram



### Monitoring and Control Process control computer system architecture



![](_page_27_Picture_2.jpeg)

### Monitoring and Control **Sub-system of diverse protections**

#### Overcoming of common mode failures

In order to implement the diversity principle, the design of the process control computer system uses a diverse protections system, based on non-programmable hardware, independent on the emergency protectioncontrol safety system

![](_page_28_Figure_3.jpeg)

![](_page_28_Picture_4.jpeg)

### System for demineralized water preparation and storage

Capacity of the plant:

- in terms of partially demineralized water for spray ponds: 90 m<sup>3</sup>/h;
- in terms of chemically demineralized water: 165 m<sup>3</sup>/h.

Water preparation stages:

- preliminary water purification, using ultrafiltration plants;
- mechanical filtration;
- ultraviolet disinfection plants;
- inverse osmosis plants;
- counterflow ion-exchange filters (APCORE technology);
- deep water demineralization through mixed-bed polishers, with external regeneration.

![](_page_29_Picture_11.jpeg)

![](_page_29_Picture_12.jpeg)

### Radioactive Waste Management Liquid Radioactive Waste

![](_page_30_Figure_1.jpeg)

## Radioactive Waste Management Solid Radioactive Waste

![](_page_31_Figure_1.jpeg)

#### Specific Features of Power Unit Commissioning Comparison of power unit indicators

Number of	VVER-1000 (Rostov Unit 3)	VVER-1200 (NV NPP)
Process systems	247	482
Pumping units	339	779
Ventilation units, ventilation plants	676	1 600
Hoisting mechanisms	35	158
Control rod drives	75	121
Motor-driven valves	4 319	6 175
Algorithms of functional control groups	34	154
Process protections, interlocks and alarms	3 686	11 140
Measuring channels	6 238	12 081
Tests in all commissioning phases	1 638	2 231

![](_page_32_Picture_2.jpeg)

#### Specific Features of Unit Commissioning Phases and key events in Power Unit 6 commissioning

lt. No.	Phases/sub-phases	Start	End	Duration, days
1	Sub-phase A-0 "Preparatory sub-phase"	30.05.2012	20.02.2015	996
2	Sub-phase A-1 "Equipment tests and tryouts"	21.02.2015	04.09.2015	195
3	Sub-phase A-3 "Reactor plant cold and hot run"	04.09.2015	19.12.2015	105
3.1	Phase A-3.1 of sub-phase A-3 "Hydraulic tests and circulation flushing of reactor plant primary circuit"	04.09.2015	06.10.2015	32
3.2	Reactor plant preparation for hot run (inter-phase inspection)	06.10.2015	10.11.2015	35
3.3	Phase A-3.2 of sub-phase A-3 "Reactor plant hot run"	11.11.2015	19.12.2015	38
4	Sub-phase A-2 "Containment tests"	19.12.2015	26.12.2015	7
5	Sub-phase A-4 "Inspection of reactor plant major components"	26.12.2015	22.03.2016	87
6	Phase B "Physical start-up"	23.03.2016		
6.1	Phase B-1.1 "Dry loading" of sub-phase B-1 "Reactor loading with nuclear fuel and tests in sub-critical state"	23.03.2016	27.03.2016	4
6.2	Phase B-1.2 "Wet loading and tests in sub-critical state" of sub- phase B-1 "Reactor loading with nuclear fuel and tests in sub- critical phase"	27.03.2016		

![](_page_33_Picture_2.jpeg)

#### Problems and Specific Features of Commissioning Activities Improved method for fuel loading into the core

![](_page_34_Figure_1.jpeg)

Phase B-1.2

Phase B-1.1

![](_page_34_Picture_4.jpeg)

#### Specific Features of Power Unit 6 Commissioning Schedule for Power Unit 6 start-up

![](_page_35_Figure_1.jpeg)

![](_page_35_Picture_2.jpeg)

#### Conclusion

In implementing the "NPP-2006" project on Novovoronezh NPP-2 site, the following main tasks meeting the state-of-the-art level of nuclear power development have been successfully solved:

Achievement of NPP safety indicators required by current standards;

Account taken of international trends in NPP safety improvement;

Maximum use of technologies and equipment proven by operating experience.

![](_page_36_Picture_5.jpeg)

![](_page_37_Picture_0.jpeg)

# Thank You for Your Attention!

![](_page_37_Picture_2.jpeg)